

Agency : ATSI
Location : Athens, OH
Tested By : BPH
Date / Time : 20 Jun 2018, 03:52 pm

DEVICE TESTED

Model : Sample
Manufacturer :
Serial Number : 123

NOTES

Sample Test Report

TEST EQUIPMENT

Model : BIUT-820
Serial Number : 820-1103
Firmware : 2.1
Software : 1.4

Setting BIU address pins to TF BIU 1
Applying 24 VDC power
Power-up Initialization Test PASS
Supply Current Test PASS
700ms Power Loss Test PASS
1500ms Power Loss Test PASS
Comm Cease Test PASS
CRC Test PASS
Response Time Test PASS
Correct Address Response Test PASS
Inputs 1-8 Recognition Test PASS
Opto Input 1-4 Recognition Test PASS
I/O 14-24 Input Recognition Test PASS
Load Switch Driver Test PASS

Setting BIU address pins to TF BIU 2
Applying 24 VDC power
Correct Address Response Test PASS
Inputs 1-8 Recognition Test PASS
Opto Input 1-4 Recognition Test PASS
I/O 16-20 Input Recognition Test PASS
Load Switch Driver Test PASS

Setting BIU address pins to TF BIU 3
Applying 24 VDC power
Correct Address Response Test PASS
Inputs 1-8 Recognition Test PASS
Opto Input 1-4 Recognition Test PASS
I/O 7-24 Input Recognition Test PASS

Setting BIU address pins to TF BIU 4
Applying 24 VDC power
Correct Address Response Test PASS
Inputs 1-8 Recognition Test PASS
Opto Input 1-4 Recognition Test PASS
I/O 10-14 Input Recognition Test PASS

Setting BIU address pins to DR BIU 1
Applying 24 VDC power
Correct Address Response Test PASS
Constant Call recognition test PASS

Setting BIU address pins to DR BIU 2
Applying 24 VDC power
Correct Address Response Test PASS
Constant Call recognition test PASS

Setting BIU address pins to DR BIU 3
Applying 24 VDC power
Correct Address Response Test PASS
Constant Call recognition test PASS

Setting BIU address pins to DR BIU 4
Applying 24 VDC power
Correct Address Response Test PASS
Constant Call recognition test PASS

Lap 1 of 1 completed 20 Jun 2018, 04:01 pm.

Serial Number 123 passed all tests.